## CERTIFICATE OF COMPLIANCE

**Certificate Number** 

20160107-EX26448

Report Reference

EX26448-20160106

**Issue Date** 

2016-JANUARY-07

Issued to:

Swastik Synergy Engineering Private Limited

No. 302 Business Suites 9 S. V. Road Santacruz West Next

to RAAS

Mumbai Maharashtra 400054 INDIA

This is to certify that representative samples of

CARBON DIOXIDE EXTINGUISHING SYSTEM UNITS, GENERAL USE

High pressure carbon dioxide extinguishing system units, stored pressure type, having nominal charging capacities of 2.0, 4.5, 6.6, 9, 22.5, 45, 53, 66, 80 and 100 kg (4.4, 10, 13, 20, 50, 100, 117, 147, 176 and 220 lbs) of Carbon Dioxide. The units have an operating pressure of 58 bar (850 psi) at 210C (70°F) with operating temperatures of -18°C to 54.4°C

(0°F to 130°F).

Have been investigated by UL in accordance with the

Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 2127 - Standard for Safety for Inert Gas Clean Agent

Extinguishing System Units.

NFPA 12 - Standard For Carbon Dioxide Extinguishing

Systems.

**Additional Information:** 

See the UL Online Certifications Directory

atwww.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.

Bruce Mahrenholz Director North

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <a href="http://ul.com/aboutul/locations/">http://ul.com/aboutul/locations/</a>

